

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

The East Windsor MUA Failed to Take Action to Bring Our Water into Compliance with a Maximum Contaminant Level (MCL) Within One Year

Our water system recently violated a New Jersey drinking water requirement. Although this incident was not an emergency, as our customers, you have a right to know what happened and what we did (are doing) to correct this situation.

Nuestro sistema de agua potable ha experimentado un fracaso a los estándares de agua consumible. Esto no es una emergencia exigente, pero usted como consumidor, tiene el derecho de tener información sobre este asunto, que puede hacer, y los pasos que estamos tomando para corregir esta situación.

Comuníquese con Richard Brand o Anthony Palombi al (609) 443-6000, 7 Wiltshire Dr. o visite nuestro sitio web en www.Eastwindsormua.com si tiene preguntas o para obtener una copia traducida de este aviso publico. ”

We routinely monitor for the presence of drinking water contaminants. During the second quarter of 2024, we exceeded the Maximum Contaminant Level (MCL) for Gross Alpha. Our water system is required to take any action necessary to bring the water system into compliance with the applicable MCL within one-year from the initial violation. Our water system failed to remediate the Gross Alpha MCL violation by the one-year deadline of July 17, 2025.

You were previously notified of the Gross Alpha MCL violation in public notice(s) issued on August 16, 2024, and November 16, 2024.

What should I do?

- There is nothing you need to do. You do not need to boil your water or take other corrective actions. However, if you have specific health concerns, consult your doctor.
- If you have a severely compromised immune system, have an infant, are pregnant, or are elderly, you may be at increased risk and should seek advice from your health care providers about drinking this water.

What does this mean?

This is not an emergency. If it had been, you would have been notified within 24 hours. *However, certain minerals are radioactive and may emit a form of radiation known as alpha radiation. Some people who drink water containing alpha emitters in excess of the MCL over many years may have an increased risk of getting cancer.*

What is being done?

- East Windsor MUA is working with the New Jersey Department of Environmental Protection (NJDEP) to evaluate the water supply and are researching options to correct the problem.
- East Windsor MUA has stopped using the identified water treatment plant since July 2024. We have increased pumping from other wells, which have no detection of Gross Alpha Particle.
- East Windsor MUA has submitted applications for permits to NJDEP (2023) on the construction of a new water treatment plant. Two new wells were drilled in 2021 and 2022 for this project.
- East Windsor MUA has increased the frequency of testing the water for Gross Alpha Particle Activity at all its wells.

For more information, please contact Richard Brand or Anthony Palombi at 609-443-6000. You can also visit our web site at www.Eastwindsormua.com

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by East Windsor Municipal Utilities Authority (PWSID# NJ1101002). Date distributed: October 15, 2025